

**ADDENDA  
TO  
THE TENDER DOCUMENT**

**Repair and Renovation of Civil & Electrical Works for  
'Copyright Board & Copyright Office (CRB&CRO)' at August  
Kranti Bhawan, Bhikaji Kama Place, New Delhi**

**ADDENDA NO-I**

**MAY, 2014**



**EdCIL (India) Limited**  
*(A Government of India Enterprise)*  
**Ed.CIL House, 18 – A, Sector 16 A**  
**Noida – 201301**

Repair & Renovation of Civil & Electrical works for CRB&CRO at August Kranti Bhawan, Bhikaji Kama Place, New Delhi

S.No.	Volume	Queries	Clarifications
(i).	Volume-IV	Agencies requested for Model/Make No. of various items given in the Bill of quantities.	The items in the Bill of Quantities (Volume-IV) for Item No. 18, 19, 30, 33, 34, 35 & 41 are as per the DSR-2013. The agency may quote their rates accordingly.
			The items in the Bill of Quantities (Volume-IV) for Item No. 32 & 40 makes & Code is as follows :  Item No. 32- Hindware -Armada-Code-F260002 or Equivalent  Item No. 40- Hindware-F870003 or Equivalent
(ii).	-	Agencies requested for drawings	The indicative drawings of ground floor & first floor is uploaded on Website and shall be a part of Tender Documents.

S.No.	Sub-Head No.	Item No.	Page	Line	Volume	To be Read	Typed
iii)	4.0 DG SETS 4.1 General Specifications	6 Scope of work	29-30	-	Volume-V	DG set is required to be supplied with acoustic enclosure as per CPCB norms. DG set with acoustic enclosure shall preferably be installed outside the building & location should be finalized in consultation with <b>EdCIL</b> . However, DG set should be as near to Essential LT panel as possible. Associated AMF panel/ Electrical panel of the DG set can be located inside the acoustic enclosure or outside the acoustic enclosure as per manufacturer standard. In case, AMF/Electrical panel has to be installed outside the acoustic enclosure, location of room to house AMF/Electrical panel should be decided in consultation with the <b>EdCIL</b> so that it shall be as near to the acoustic enclosure as possible.	DG set is required to be supplied with acoustic enclosure as per CPCB norms. DG set with acoustic enclosure shall preferably be installed outside the building & location should be finalized in consultation with <b>NTPC</b> . However, DG set should be as near to Essential LT panel as possible. Associated AMF panel/ Electrical panel of the DG set can be located inside the acoustic enclosure or outside the acoustic enclosure as per manufacturer standard. In case, AMF/Electrical panel has to be installed outside the acoustic enclosure, location of room to house AMF/Electrical panel should be decided in consultation with the <b>NTPC</b> so that it shall be as near to the acoustic enclosure as possible.